Power Line Systems

2019 PLS-CADD Advanced Training and User Group

69KV Project Replacing w/ HTLS Conductors

by Ryan "Ralphie" Adams Arizona Public Service



IT'S ALL ABOUT YOUR POWER LINES



IT'S THE SOLUTION

69kV Conductor Upgrade Project (AA \rightarrow ACSS "ish")



- No structures are to be replaced...???
- Only conductor to be replaced for upgrade
- OPGW installation requested also...

Power Line Systems, Inc.

6/21/2019



EAST Section





Power Line Systems, Inc.

6/21/2019

3

WEST Section





6/21/2019

Power Line Systems, Inc.



 Δ

4

Structure Modeling

- Towers

- 1960's vintage Generation Station Towers
- 1970's vintage Tangent and DE Towers
 - Tower drawings difficult to find and limited in model detailing

- PJ Ford

- Tower modeling support
 - Ongoing engineering support for remediation activities...





Structure Modeling

- Poles

Existing Steel and wood pole structures

9





6/21/2019

Power Line Systems, Inc. 6

Conductor Type Selection

- Normal upgrade conductor = 795 "Tern" ACSS
 - does not work due to sag / clearance and structure loading issues
- Multiple Manufactures for Specialized Conductor selection
 - Need to follow specs for Arbutus (existing conductor) but also need to support 1600 amp ratings (AZ Summer environment)
 - Need to maintain or reduce loading on existing structures
 - Need to be installed at same or reduced tension compared to Arbutus

	Project Lines			
	As-Built , Cost=0, 32 Structures, 41 Sections, Show, Min Span=44, Max Span=1199, Created 4:03:53 PM 2/1/20			
	795 ACSS (Proposed) , Cost=0, 32 Structures, 41 Sections, Show, Min Span=44, Max Span=1199, Created 6:45:0			
	Option 1a , Cost=0, 32 Structures, 41 Sections, Show, Min Span=44, Max Span=1199, Created 12:56:46 PM 6/9/			
	Option 1b , Cost=0, 32 Structures, 41 Sections, Show, Min Span=44, Max Span=1199, Created 1:29:30 PM 6/9/2			
	Option 2a , Cost=0, 32 Structures, 41 Sections, Show, Min Span=44, Max Span=1199, Created 1:34:30 PM 6/9/2			
	Option 3a , Cost=0, 32 Structures, 41 Sections, Show, Min Span=44, Max Span=1199, Created 1:45:33 PM 6/9/2			
	Option 3b , Cost=0, 32 Structures, 41 Sections, Show, Min Span=44, Max Span=1199, Created 1:39:12 PM 6/9/2			
- 1				

Clearances vs. Tension

Due to span lengths and existing structures... Graphical Sagging was used for fitting conductor(s) to the existing terrain.



6/21/2019

Power Line Systems, Inc.

8

Clearances vs. Tension with Graphical Sagging



6/21/2019

Structure Remediation – per Conductor Type

Tower member over-stress based on Conductor Selection

As-Built Ar	butus
% of RBS @ 60 Deg F Init	ial FE 22.5
A612	Max of
	Maximum
Row Labels	🗾 Usage %
	164.03
• 3pole_DblCkt_DDE.pol	224.99
Angle Dead End With PCS+00BE+35LE.tow	159.74
20	159.74
27	127.86
28	155.36
· E-17801 230 DCT.tow	115.48
. E-17801 230 DCT+00BE+LE-10-10-10-10.to	w 167.99
· E-17801 230 DCT+00BE+LE-35-35-35-35.to	w 306.29
· E-18604 230 DCA-1.TOW	128.65
• E-18610 0°-90° Angle Dead End Family.tow	/ 136.06
@ G-13910 90° Turn Tower - 4 Circuit-96.5.TO	W 140.85
Grand Total	306.29

% of RBS @ 60 Deg F Initial FE	55.6
Row Labels	Max of Maximum Usage %
2-pole tangent str sd guy dn guys.pol	164.03
Bole_DblCkt_DDE.pol	224.98
Angle Dead End With PCS+00BE+35LE.tow	164.06
20	155.98
28	164.06
27	134.31
. E-17801 230 DCT.tow	107.64
. E-17801 230 DCT+00BE+LE-10-10-10-10.tow	122.25
. E-17801 230 DCT+00BE+LE-35-35-35-35.tow	135.64
E-18610 0°-90° Angle Dead End Family.tow	136.06
G-13910 90° Turn Tower - 4 Circuit-96.5.TOW	128.27
RioSalado TangentDropPole.pol	229.68
RioSaladoSub DE Drop Pole.pol	300.51
Grand Total	300.51

	Option 1A	
% of RBS @ 60) Deg F Initial FE	26.7
-NEE	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Max of
94-		Maximum
low Labels		Usage %
• 2-pole tangent str sd gwy dn guy	vs.pol 1	164.03
3pole_DblCkt_DDE.pol		224.99
Angle Dead End With PCS 1998	35LE.tow	144.6
28 0 1		129.3
27	101	113.7
28		144.66
E-17801 230 DCT tow		102.
E-17801 230 DCT+001E+LE-10-1	8-10-10.tow	114.14
E-17801 230 DCT+00BE+LE-35-3	5-35-35.tow	125.5
E-18610 0°-90 Angle Dead End	Family.tow	136.0
• G-13910 90° Turn Tower - 4 Circ	uit-96.5.TOW	136.87
Grand Total		224.99
	Option 1B	
% of RBS @ 60	Deg F Initial FE	21.8

% of KBS @ 60 Deg F Initial F	E 21.8
920	Max of Maximum
Row Labels	Usage %
2-pole tangent str sd guy dn guys.pol	164.03
• 3pole_DblCkt_DDE.pol	224.99
Angle Dead End With PCS+00BE+35LE.tow	150.47
20	138.54
27	116.44
28	150.47
• E-17801 230 DCT.tow	106.08
· E-17801 230 DCT+00BE+LE-10-10-10.tow	119.82
. E-17801 230 DCT+00BE+LE-35-35-35-35.tow	131.77
• E-18610 0°-90° Angle Dead End Family.tow	136.06
. G-13910 90° Turn Tower - 4 Circuit-96.5.TOW	140.47
Grand Total	224.99

0	Option 2A	
20 % of RE	3S @ 60 Deg F Initial FE	14.2
		Vlax of
375	<u> </u>	Maximum
Row Labels		Jsage %
2-pole tangent str sd guy	dn guys.pol	164.0
3pole_DblCkt_DDE.pol		224.9
Angle Dead End With PC	S+00BE+35LE.tow	127.5
20		127.5
27		102.8
28		121.5
. E-17801 230 DCT+00BE+	LE 10-10-10-10 tow	111
· E-17801 230 DCT-00BE	LE-35-35-35-35.tow	119.3
⊕ E-18610 0°-59 Angle De	ad End Family.tow	136.0
. G-13910 90° Turn Tower	- 4 Circuit-96.5.TOW	128.2
Grand Total		224.9

Option	2A	
🔜 🗸 😳 % of RBS @ 60 Deg F Initial	FE	25
3920		
Row Labels	•	Max of Max
• 2-pole tangent str sd guy dn guys.pol		164.03
• 3pole_DblCkt_DDE.pol		224.97
Angle Dead End With PCS+00BE+35LE.tow		153.37
20		140.48
27		116.36
28		153.37
· E-17801 230 DCT+00BE+LE-10-10-10.tow		112.54
· E-17801 230 DCT+00BE+LE-35-35-35.tow		124.78
		136.06
⊕ G-13910 90° Turn Tower - 4 Circuit-96.5.TOW		128.24
Grand Total		224.97

2-pole tangent s 3pole DblCkt Angle Dead En

E-17801 • E-17801 + E-17801 230 E-18610 0°-90° . G-13910 90° Tur Grand Total

2-nole tangent

Angle Dead Fr · E-17801 230 DO

E-17801 23 F-18610 0°-90 G-13910 90° Tur

Grand Total

Power Line Systems, Inc.



Option 3A	
% of RBS @ 60 Deg F Initial FE	32.6
\wedge	Max of
	Maximum
	Usage %
r sd guy dn guys pol	164.03
DE.pol	224.97
With PCS+008E+35LE.tow	127.58
	127.58
	112.18
	116.3
.tot	102.75
+008E+LE-10-10-10.tow	114.47
+00BE+LE-35-35-35-35.tow	125.04
ngle Dead End Family.tow	136.06
Tower - 4 Circuit-96.5.TOW	128.25
	224.97

Option 3E	3
% of RBS @ 60 Deg F Initial FE	36.5
	Max of Maximum Usage %
r sd guy dn guys pol	164.03 224.98
With FESTODBE+35LE.tow	149.12 135.28
Tensie	149.12 103.26
+009E+LE-10-10-10-10.tow +00BE+LE-35-35-35-35.tow	116.58 128.26
ngle Dead End Family.tow 1 Tower - 4 Circuit-96.5.TOW	136.06 128.25
	224.98

Conclusion

- Model Towers don't take short cuts
 - Modeling the towers shows that the as-built conditions produce overloaded members, not expected...
 - Also allows the user to identify unknown capacities that may be used if needed
- **Conductor Manufacturers**
 - Using multiple WIR files from various manufacturers was helpful to better refine the potential installation solutions (alternate tensions, etc.)
- Specialized Conductors vs. Traditional Upgrade Methods
 - Evaluating a range of specialized conductor options could and some times will be less expensive than doing a full rebuild

Power Line Systems





IT'S ALL ABOUT YOUR POWER LINES

FAC 008/009 LiDAR Modeling CSA Distribution Line Optimization

GO95



Ralphie.Adams@APS.com

IT'S THE SOLUTION